



Wednesday, October 05, 2016

Mr. Joe Scollan  
Bee & Jay Water Systems  
P.O. Box 78 Route 6  
Mahopac, NY 10541

Project ID: PUT VAL ELEM SCHOOL  
Sample ID#s: BV29518 - BV29564

This laboratory is in compliance with the NELAC requirements of procedures used except where indicated.

This report contains results for the parameters tested, under the sampling conditions described on the Chain Of Custody, as received by the laboratory.

A scanned version of the COC form accompanies the analytical report and is an exact duplicate of the original.

If you have any questions concerning this testing, please do not hesitate to contact Phoenix Client Services at ext. 200.

Sincerely yours,

A handwritten signature in black ink that reads "Phyllis Shiller". The signature is written in a cursive style with a large initial "P".

Phyllis Shiller  
Laboratory Director

NELAC - #NY11301  
CT Lab Registration #PH-0618  
MA Lab Registration #MA-CT-007  
ME Lab Registration #CT-007  
NH Lab Registration #213693-A,B

NJ Lab Registration #CT-003  
NY Lab Registration #11301  
PA Lab Registration #68-03530  
RI Lab Registration #63  
VT Lab Registration #VT11301



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 October 05, 2016

FOR: Mr. Joe Scollan  
 Bee & Jay Water Systems  
 P.O. Box 78 Route 6  
 Mahopac, NY 10541

Sample Information

Matrix: DRINKING WATER  
 Location Code: BEEJAYPVS  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: HW  
 Received by: B  
 Analyzed by: see "By" below

Date

09/27/16  
 09/27/16

Time

16:49

Laboratory Data

SDG ID: GBV29518  
 Phoenix ID: BV29518

Project ID: PUT VAL ELEM SCHOOL  
 Client ID: 2ND FLOOR GIRLS BATH LEFT

| Parameter  | Result    | RL/<br>PQL | DIL | Units | AL    | MCL | MCLG | Date/Time | By       | Reference         |
|--|-----------|------------|-----|-------|-------|-----|------|-----------|----------|-------------------|
| Lead   | 0.015     | 0.002      | 4   | mg/L  | 0.015 |     |      | 09/30/16  | MA/TH    | E200.9/SM3113B-10 |
| *** Lead is greater than or equal to Action Level of 0.015 *** |           |            |     |       |       |     |      |           |          |                   |
| Total Metal Digestion  | Completed |            |     |       |       |     |      | 09/28/16  | /RVM/AG/ | E200.9            |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 05, 2016**

**Reviewed and Released by: Deb Lawrie, Project Manager**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 October 05, 2016

FOR: Mr. Joe Scollan  
 Bee & Jay Water Systems  
 P.O. Box 78 Route 6  
 Mahopac, NY 10541

Sample Information

Matrix: DRINKING WATER  
 Location Code: BEEJAYPVS  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: HW  
 Received by: B  
 Analyzed by: see "By" below

Date                      Time  
 09/27/16  
 09/27/16                      16:49

Laboratory Data

SDG ID: GBV29518  
 Phoenix ID: BV29519

Project ID: PUT VAL ELEM SCHOOL  
 Client ID: 2ND FLOOR FOUNTAIN HALL

| Parameter             | Result    | RL/<br>PQL | DIL | Units | AL    | MCL | MCLG | Date/Time | By      | Reference         |
|-----------------------|-----------|------------|-----|-------|-------|-----|------|-----------|---------|-------------------|
| Lead                  | 0.001     | 0.001      | 1   | mg/L  | 0.015 |     |      | 09/30/16  | MA/TH   | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed |            |     |       |       |     |      | 09/28/16  | /RVMAG/ | E200.9            |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 05, 2016**

**Reviewed and Released by: Deb Lawrie, Project Manager**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 October 05, 2016

FOR: Mr. Joe Scollan  
 Bee & Jay Water Systems  
 P.O. Box 78 Route 6  
 Mahopac, NY 10541

Sample Information

Matrix: DRINKING WATER  
 Location Code: BEEJAYPVS  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: HW  
 Received by: B  
 Analyzed by: see "By" below

Date                      Time  
 09/27/16  
 09/27/16                      16:49

Laboratory Data

SDG ID: GBV29518  
 Phoenix ID: BV29520

Project ID: PUT VAL ELEM SCHOOL  
 Client ID: 2ND FLOOR BOYS ROOM LEFT

| Parameter             | Result    | RL/<br>PQL | DIL | Units | AL    | MCL | MCLG | Date/Time | By      | Reference         |
|-----------------------|-----------|------------|-----|-------|-------|-----|------|-----------|---------|-------------------|
| Lead                  | 0.013     | 0.002      | 4   | mg/L  | 0.015 |     |      | 09/30/16  | MA/TH   | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed |            |     |       |       |     |      | 09/28/16  | /RVMAG/ | E200.9            |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 05, 2016**

**Reviewed and Released by: Deb Lawrie, Project Manager**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 October 05, 2016

FOR: Mr. Joe Scollan  
 Bee & Jay Water Systems  
 P.O. Box 78 Route 6  
 Mahopac, NY 10541

Sample Information

Matrix: DRINKING WATER  
 Location Code: BEEJAYPVS  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: HW  
 Received by: B  
 Analyzed by: see "By" below

Date

09/27/16  
 09/27/16

Time

16:49

Laboratory Data

SDG ID: GBV29518  
 Phoenix ID: BV29521

Project ID: PUT VAL ELEM SCHOOL  
 Client ID: NEW WING BOYS BATH LEFT

| Parameter             | Result    | RL/<br>PQL | DIL | Units | AL    | MCL | MCLG | Date/Time | By      | Reference         |
|-----------------------|-----------|------------|-----|-------|-------|-----|------|-----------|---------|-------------------|
| Lead                  | 0.001     | 0.001      | 1   | mg/L  | 0.015 |     |      | 09/30/16  | MA/TH   | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed |            |     |       |       |     |      | 09/28/16  | /RVMAG/ | E200.9            |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 05, 2016**

**Reviewed and Released by: Deb Lawrie, Project Manager**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 05, 2016

FOR: Mr. Joe Scollan  
 Bee & Jay Water Systems  
 P.O. Box 78 Route 6  
 Mahopac, NY 10541

Sample Information

Matrix: DRINKING WATER  
 Location Code: BEEJAYPVS  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: HW  
 Received by: B  
 Analyzed by: see "By" below

Date

09/27/16  
 09/27/16

Time

16:49

## Laboratory Data

SDG ID: GBV29518  
 Phoenix ID: BV29522

Project ID: PUT VAL ELEM SCHOOL  
 Client ID: 1129 FOUNTAIN

| Parameter             | Result    | RL/<br>PQL | DIL | Units | AL    | MCL | MCLG | Date/Time | By      | Reference         |
|-----------------------|-----------|------------|-----|-------|-------|-----|------|-----------|---------|-------------------|
| Lead                  | 0.005     | 0.002      | 4   | mg/L  | 0.015 |     |      | 09/30/16  | MA/TH   | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed |            |     |       |       |     |      | 09/28/16  | /RVMAG/ | E200.9            |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 05, 2016**

**Reviewed and Released by: Deb Lawrie, Project Manager**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 October 05, 2016

FOR: Mr. Joe Scollan  
 Bee & Jay Water Systems  
 P.O. Box 78 Route 6  
 Mahopac, NY 10541

Sample Information

Matrix: DRINKING WATER  
 Location Code: BEEJAYPVS  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: HW  
 Received by: B  
 Analyzed by: see "By" below

Date

09/27/16  
 09/27/16

Time

16:49

Laboratory Data

SDG ID: GBV29518  
 Phoenix ID: BV29523

Project ID: PUT VAL ELEM SCHOOL  
 Client ID: 1103 BATH SINK

| Parameter  | Result    | RL/<br>PQL | DIL | Units | AL    | MCL | MCLG | Date/Time | By       | Reference         |
|--|-----------|------------|-----|-------|-------|-----|------|-----------|----------|-------------------|
| Lead   | 0.022     | 0.002      | 4   | mg/L  | 0.015 |     |      | 09/30/16  | MA/TH    | E200.9/SM3113B-10 |
| *** Lead is greater than or equal to Action Level of 0.015 *** |           |            |     |       |       |     |      |           |          |                   |
| Total Metal Digestion  | Completed |            |     |       |       |     |      | 09/28/16  | /RVM/AG/ | E200.9            |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 05, 2016**

**Reviewed and Released by: Deb Lawrie, Project Manager**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 October 05, 2016

FOR: Mr. Joe Scollan  
 Bee & Jay Water Systems  
 P.O. Box 78 Route 6  
 Mahopac, NY 10541

Sample Information

Matrix: DRINKING WATER  
 Location Code: BEEJAYPVS  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: HW  
 Received by: B  
 Analyzed by: see "By" below

Date                      Time  
 09/27/16  
 09/27/16                      16:49

Laboratory Data

SDG ID: GBV29518  
 Phoenix ID: BV29524

Project ID: PUT VAL ELEM SCHOOL  
 Client ID: 2ND FLOOR BOYS ROOM RIGHT

| Parameter             | Result    | RL/<br>PQL | DIL | Units | AL    | MCL | MCLG | Date/Time | By      | Reference         |
|-----------------------|-----------|------------|-----|-------|-------|-----|------|-----------|---------|-------------------|
| Lead                  | 0.005     | 0.002      | 4   | mg/L  | 0.015 |     |      | 09/30/16  | MA/TH   | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed |            |     |       |       |     |      | 09/28/16  | /RVMAG/ | E200.9            |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 05, 2016**

**Reviewed and Released by: Deb Lawrie, Project Manager**





**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 October 05, 2016

FOR: Mr. Joe Scollan  
 Bee & Jay Water Systems  
 P.O. Box 78 Route 6  
 Mahopac, NY 10541

Sample Information

Matrix: DRINKING WATER  
 Location Code: BEEJAYPVS  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: HW  
 Received by: B  
 Analyzed by: see "By" below

Date                      Time  
 09/27/16  
 09/27/16                      16:49

Laboratory Data

SDG ID: GBV29518  
 Phoenix ID: BV29525

Project ID: PUT VAL ELEM SCHOOL  
 Client ID: 1040 SINK

| Parameter             | Result    | RL/<br>PQL | DIL | Units | AL    | MCL | MCLG | Date/Time | By      | Reference         |
|-----------------------|-----------|------------|-----|-------|-------|-----|------|-----------|---------|-------------------|
| Lead                  | 0.007     | 0.002      | 4   | mg/L  | 0.015 |     |      | 09/30/16  | MA/TH   | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed |            |     |       |       |     |      | 09/28/16  | /RVMAG/ | E200.9            |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 05, 2016**

**Reviewed and Released by: Deb Lawrie, Project Manager**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 05, 2016

FOR: Mr. Joe Scollan  
 Bee & Jay Water Systems  
 P.O. Box 78 Route 6  
 Mahopac, NY 10541

Sample Information

Matrix: DRINKING WATER  
 Location Code: BEEJAYPVS  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: HW  
 Received by: B  
 Analyzed by: see "By" below

Date

09/27/16  
 09/27/16

Time

16:49

## Laboratory Data

SDG ID: GBV29518  
 Phoenix ID: BV29526

Project ID: PUT VAL ELEM SCHOOL  
 Client ID: 1077 SINK

| Parameter             | Result    | RL/<br>PQL | DIL | Units | AL    | MCL | MCLG | Date/Time | By      | Reference         |
|-----------------------|-----------|------------|-----|-------|-------|-----|------|-----------|---------|-------------------|
| Lead                  | 0.008     | 0.002      | 4   | mg/L  | 0.015 |     |      | 09/30/16  | MA/TH   | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed |            |     |       |       |     |      | 09/28/16  | /RVMAG/ | E200.9            |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 05, 2016**

**Reviewed and Released by: Deb Lawrie, Project Manager**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 October 05, 2016

FOR: Mr. Joe Scollan  
 Bee & Jay Water Systems  
 P.O. Box 78 Route 6  
 Mahopac, NY 10541

Sample Information

Matrix: DRINKING WATER  
 Location Code: BEEJAYPVS  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: HW  
 Received by: B  
 Analyzed by: see "By" below

Date                      Time  
 09/27/16  
 09/27/16                      16:49

Laboratory Data

SDG ID: GBV29518  
 Phoenix ID: BV29527

Project ID: PUT VAL ELEM SCHOOL  
 Client ID: 2ND FLOOR GIRLS BATH RIGHT

| Parameter             | Result    | RL/<br>PQL | DIL | Units | AL    | MCL | MCLG | Date/Time | By      | Reference         |
|-----------------------|-----------|------------|-----|-------|-------|-----|------|-----------|---------|-------------------|
| Lead                  | 0.008     | 0.002      | 4   | mg/L  | 0.015 |     |      | 09/30/16  | MA/TH   | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed |            |     |       |       |     |      | 09/28/16  | /RVMAG/ | E200.9            |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 05, 2016**

**Reviewed and Released by: Deb Lawrie, Project Manager**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 October 05, 2016

FOR: Mr. Joe Scollan  
 Bee & Jay Water Systems  
 P.O. Box 78 Route 6  
 Mahopac, NY 10541

Sample Information

Matrix: DRINKING WATER  
 Location Code: BEEJAYPVS  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: HW  
 Received by: B  
 Analyzed by: see "By" below

Date Time

09/27/16  
 09/27/16 16:49

Laboratory Data

SDG ID: GBV29518  
 Phoenix ID: BV29528

Project ID: PUT VAL ELEM SCHOOL  
 Client ID: MAIN FLOOR GIRLS BATH RIGHT

| Parameter             | Result    | RL/<br>PQL | DIL | Units | AL    | MCL | MCLG | Date/Time | By      | Reference         |
|-----------------------|-----------|------------|-----|-------|-------|-----|------|-----------|---------|-------------------|
| Lead                  | 0.003     | 0.002      | 4   | mg/L  | 0.015 |     |      | 09/30/16  | MA/TH   | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed |            |     |       |       |     |      | 09/28/16  | /RVMAG/ | E200.9            |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 05, 2016**

**Reviewed and Released by: Deb Lawrie, Project Manager**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 October 05, 2016

FOR: Mr. Joe Scollan  
 Bee & Jay Water Systems  
 P.O. Box 78 Route 6  
 Mahopac, NY 10541

Sample Information

Matrix: DRINKING WATER  
 Location Code: BEEJAYPVS  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: HW  
 Received by: B  
 Analyzed by: see "By" below

Date

09/27/16  
 09/27/16

Time

16:49

Laboratory Data

SDG ID: GBV29518  
 Phoenix ID: BV29529

Project ID: PUT VAL ELEM SCHOOL  
 Client ID: NEW WING FOUNTAIN TALL

| Parameter             | Result    | RL/<br>PQL | DIL | Units | AL    | MCL | MCLG | Date/Time | By      | Reference         |
|-----------------------|-----------|------------|-----|-------|-------|-----|------|-----------|---------|-------------------|
| Lead                  | 0.001     | 0.001      | 1   | mg/L  | 0.015 |     |      | 09/30/16  | MA/TH   | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed |            |     |       |       |     |      | 09/28/16  | /RVMAG/ | E200.9            |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 05, 2016**

**Reviewed and Released by: Deb Lawrie, Project Manager**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 October 05, 2016

FOR: Mr. Joe Scollan  
 Bee & Jay Water Systems  
 P.O. Box 78 Route 6  
 Mahopac, NY 10541

Sample Information

Matrix: DRINKING WATER  
 Location Code: BEEJAYPVS  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: HW  
 Received by: B  
 Analyzed by: see "By" below

Date

09/27/16  
 09/27/16

Time

16:49

Laboratory Data

SDG ID: GBV29518  
 Phoenix ID: BV29530

Project ID: PUT VAL ELEM SCHOOL  
 Client ID: 1107 BATH SINK

| Parameter             | Result    | RL/<br>PQL | DIL | Units | AL    | MCL | MCLG | Date/Time | By      | Reference         |
|-----------------------|-----------|------------|-----|-------|-------|-----|------|-----------|---------|-------------------|
| Lead                  | 0.006     | 0.002      | 4   | mg/L  | 0.015 |     |      | 09/30/16  | MA/TH   | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed |            |     |       |       |     |      | 09/28/16  | /RVMAG/ | E200.9            |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 05, 2016**

**Reviewed and Released by: Deb Lawrie, Project Manager**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 October 05, 2016

FOR: Mr. Joe Scollan  
 Bee & Jay Water Systems  
 P.O. Box 78 Route 6  
 Mahopac, NY 10541

Sample Information

Matrix: DRINKING WATER  
 Location Code: BEEJAYPVS  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: HW  
 Received by: B  
 Analyzed by: see "By" below

Date                      Time  
 09/27/16  
 09/27/16                      16:49

Laboratory Data

SDG ID: GBV29518  
 Phoenix ID: BV29531

Project ID: PUT VAL ELEM SCHOOL  
 Client ID: MAIN FLOOR GIRLS BATH LEFT

| Parameter             | Result    | RL/<br>PQL | DIL | Units | AL    | MCL | MCLG | Date/Time | By      | Reference         |
|-----------------------|-----------|------------|-----|-------|-------|-----|------|-----------|---------|-------------------|
| Lead                  | 0.003     | 0.002      | 4   | mg/L  | 0.015 |     |      | 09/30/16  | MA/TH   | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed |            |     |       |       |     |      | 09/28/16  | /RVMAG/ | E200.9            |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 05, 2016**

**Reviewed and Released by: Deb Lawrie, Project Manager**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 October 05, 2016

FOR: Mr. Joe Scollan  
 Bee & Jay Water Systems  
 P.O. Box 78 Route 6  
 Mahopac, NY 10541

Sample Information

Matrix: DRINKING WATER  
 Location Code: BEEJAYPVS  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: HW  
 Received by: B  
 Analyzed by: see "By" below

Date                      Time  
 09/27/16  
 09/27/16                      16:49

Laboratory Data

SDG ID: GBV29518  
 Phoenix ID: BV29532

Project ID: PUT VAL ELEM SCHOOL  
 Client ID: 1097 SINK

| Parameter             | Result    | RL/<br>PQL | DIL | Units | AL    | MCL | MCLG | Date/Time | By      | Reference         |
|-----------------------|-----------|------------|-----|-------|-------|-----|------|-----------|---------|-------------------|
| Lead                  | 0.014     | 0.002      | 4   | mg/L  | 0.015 |     |      | 09/30/16  | MA/TH   | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed |            |     |       |       |     |      | 09/28/16  | /RVMAG/ | E200.9            |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 05, 2016**

**Reviewed and Released by: Deb Lawrie, Project Manager**





**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 October 05, 2016

FOR: Mr. Joe Scollan  
 Bee & Jay Water Systems  
 P.O. Box 78 Route 6  
 Mahopac, NY 10541

Sample Information

Matrix: DRINKING WATER  
 Location Code: BEEJAYPVS  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: HW  
 Received by: B  
 Analyzed by: see "By" below

Date

09/27/16  
 09/27/16

Time

16:49

Laboratory Data

SDG ID: GBV29518  
 Phoenix ID: BV29533

Project ID: PUT VAL ELEM SCHOOL  
 Client ID: 1020 FOUNTAIN

| Parameter  | Result    | RL/<br>PQL | DIL | Units | AL    | MCL | MCLG | Date/Time | By       | Reference         |
|--|-----------|------------|-----|-------|-------|-----|------|-----------|----------|-------------------|
| Lead   | 0.231     | 0.005      | 10  | mg/L  | 0.015 |     |      | 09/30/16  | MA/TH    | E200.9/SM3113B-10 |
| *** Lead is greater than or equal to Action Level of 0.015 *** |           |            |     |       |       |     |      |           |          |                   |
| Total Metal Digestion  | Completed |            |     |       |       |     |      | 09/28/16  | /RVM/AG/ | E200.9            |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 05, 2016**

**Reviewed and Released by: Deb Lawrie, Project Manager**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 October 05, 2016

FOR: Mr. Joe Scollan  
 Bee & Jay Water Systems  
 P.O. Box 78 Route 6  
 Mahopac, NY 10541

Sample Information

Matrix: DRINKING WATER  
 Location Code: BEEJAYPVS  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: HW  
 Received by: B  
 Analyzed by: see "By" below

Date                      Time  
 09/27/16  
 09/27/16                      16:49

Laboratory Data

SDG ID: GBV29518  
 Phoenix ID: BV29534

Project ID: PUT VAL ELEM SCHOOL  
 Client ID: 1117 FOUNTAIN

| Parameter             | Result    | RL/<br>PQL | DIL | Units | AL    | MCL | MCLG | Date/Time | By      | Reference         |
|-----------------------|-----------|------------|-----|-------|-------|-----|------|-----------|---------|-------------------|
| Lead                  | 0.005     | 0.002      | 4   | mg/L  | 0.015 |     |      | 09/30/16  | MA/TH   | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed |            |     |       |       |     |      | 09/28/16  | /RVMAG/ | E200.9            |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 05, 2016**

**Reviewed and Released by: Deb Lawrie, Project Manager**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 October 05, 2016

FOR: Mr. Joe Scollan  
 Bee & Jay Water Systems  
 P.O. Box 78 Route 6  
 Mahopac, NY 10541

Sample Information

Matrix: DRINKING WATER  
 Location Code: BEEJAYPVS  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: HW  
 Received by: B  
 Analyzed by: see "By" below

Date                      Time  
 09/27/16  
 09/27/16                      16:49

Laboratory Data

SDG ID: GBV29518  
 Phoenix ID: BV29535

Project ID: PUT VAL ELEM SCHOOL  
 Client ID: 1117 SINK

| Parameter             | Result    | RL/<br>PQL | DIL | Units | AL    | MCL | MCLG | Date/Time | By      | Reference         |
|-----------------------|-----------|------------|-----|-------|-------|-----|------|-----------|---------|-------------------|
| Lead                  | 0.012     | 0.005      | 10  | mg/L  | 0.015 |     |      | 09/30/16  | MA/TH   | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed |            |     |       |       |     |      | 09/28/16  | /RVMAG/ | E200.9            |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 05, 2016**

**Reviewed and Released by: Deb Lawrie, Project Manager**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 05, 2016

FOR: Mr. Joe Scollan  
 Bee & Jay Water Systems  
 P.O. Box 78 Route 6  
 Mahopac, NY 10541

Sample Information

Matrix: DRINKING WATER  
 Location Code: BEEJAYPVS  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: HW  
 Received by: B  
 Analyzed by: see "By" below

Date Time

09/27/16  
 09/27/16 16:49

## Laboratory Data

SDG ID: GBV29518  
 Phoenix ID: BV29536

Project ID: PUT VAL ELEM SCHOOL  
 Client ID: 3RD FLOOR FACULTY BATH

| Parameter             | Result    | RL/<br>PQL | DIL | Units | AL    | MCL | MCLG | Date/Time | By      | Reference         |
|-----------------------|-----------|------------|-----|-------|-------|-----|------|-----------|---------|-------------------|
| Lead                  | 0.008     | 0.002      | 4   | mg/L  | 0.015 |     |      | 09/30/16  | MA/TH   | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed |            |     |       |       |     |      | 09/28/16  | /RVMAG/ | E200.9            |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 05, 2016**

**Reviewed and Released by: Deb Lawrie, Project Manager**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 October 05, 2016

FOR: Mr. Joe Scollan  
 Bee & Jay Water Systems  
 P.O. Box 78 Route 6  
 Mahopac, NY 10541

Sample Information

Matrix: DRINKING WATER  
 Location Code: BEEJAYPVS  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: HW  
 Received by: B  
 Analyzed by: see "By" below

Date Time

09/27/16  
 09/27/16 16:49

Laboratory Data

SDG ID: GBV29518  
 Phoenix ID: BV29537

Project ID: PUT VAL ELEM SCHOOL  
 Client ID: NEW WING FACULTY BATH

| Parameter             | Result    | RL/<br>PQL | DIL | Units | AL    | MCL | MCLG | Date/Time | By      | Reference         |
|-----------------------|-----------|------------|-----|-------|-------|-----|------|-----------|---------|-------------------|
| Lead                  | 0.005     | 0.002      | 4   | mg/L  | 0.015 |     |      | 09/30/16  | MA/TH   | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed |            |     |       |       |     |      | 09/28/16  | /RVMAG/ | E200.9            |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 05, 2016**

**Reviewed and Released by: Deb Lawrie, Project Manager**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 October 05, 2016

FOR: Mr. Joe Scollan  
 Bee & Jay Water Systems  
 P.O. Box 78 Route 6  
 Mahopac, NY 10541

Sample Information

Matrix: DRINKING WATER  
 Location Code: BEEJAYPVS  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: HW  
 Received by: B  
 Analyzed by: see "By" below

Date

09/27/16  
 09/27/16

Time

16:49

Laboratory Data

SDG ID: GBV29518  
 Phoenix ID: BV29538

Project ID: PUT VAL ELEM SCHOOL  
 Client ID: 1126 BATH SINK

| Parameter  | Result    | RL/<br>PQL | DIL | Units | AL    | MCL | MCLG | Date/Time | By       | Reference         |
|--|-----------|------------|-----|-------|-------|-----|------|-----------|----------|-------------------|
| Lead   | 0.025     | 0.002      | 4   | mg/L  | 0.015 |     |      | 09/30/16  | MA/TH    | E200.9/SM3113B-10 |
| *** Lead is greater than or equal to Action Level of 0.015 *** |           |            |     |       |       |     |      |           |          |                   |
| Total Metal Digestion  | Completed |            |     |       |       |     |      | 09/28/16  | /RVM/AG/ | E200.9            |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 05, 2016**

**Reviewed and Released by: Deb Lawrie, Project Manager**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 October 05, 2016

FOR: Mr. Joe Scollan  
 Bee & Jay Water Systems  
 P.O. Box 78 Route 6  
 Mahopac, NY 10541

Sample Information

Matrix: DRINKING WATER  
 Location Code: BEEJAYPVS  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: HW  
 Received by: B  
 Analyzed by: see "By" below

Date                      Time  
 09/27/16  
 09/27/16                      16:49

Laboratory Data

SDG ID: GBV29518  
 Phoenix ID: BV29539

Project ID: PUT VAL ELEM SCHOOL  
 Client ID: MAIN HALL FOUNTAIN

| Parameter             | Result    | RL/<br>PQL | DIL | Units | AL    | MCL | MCLG | Date/Time | By      | Reference         |
|-----------------------|-----------|------------|-----|-------|-------|-----|------|-----------|---------|-------------------|
| Lead                  | 0.001     | 0.001      | 1   | mg/L  | 0.015 |     |      | 09/30/16  | MA/TH   | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed |            |     |       |       |     |      | 09/28/16  | /RVMAG/ | E200.9            |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 05, 2016**

**Reviewed and Released by: Deb Lawrie, Project Manager**



Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 October 05, 2016

FOR: Mr. Joe Scollan  
 Bee & Jay Water Systems  
 P.O. Box 78 Route 6  
 Mahopac, NY 10541

Sample Information

Matrix: DRINKING WATER  
 Location Code: BEEJAYPVS  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: HW  
 Received by: B  
 Analyzed by: see "By" below

Date

09/27/16  
 09/27/16

Time

16:49

Laboratory Data

SDG ID: GBV29518  
 Phoenix ID: BV29540

Project ID: PUT VAL ELEM SCHOOL  
 Client ID: 3004 SINK

| Parameter  | Result    | RL/<br>PQL | DIL | Units | AL    | MCL | MCLG | Date/Time | By       | Reference         |
|--|-----------|------------|-----|-------|-------|-----|------|-----------|----------|-------------------|
| Lead   | 0.053     | 0.002      | 4   | mg/L  | 0.015 |     |      | 09/30/16  | MA/TH    | E200.9/SM3113B-10 |
| *** Lead is greater than or equal to Action Level of 0.015 *** |           |            |     |       |       |     |      |           |          |                   |
| Total Metal Digestion  | Completed |            |     |       |       |     |      | 09/28/16  | /RVM/AG/ | E200.9            |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

Phyllis Shiller, Laboratory Director

October 05, 2016

Reviewed and Released by: Deb Lawrie, Project Manager





**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 October 05, 2016

FOR: Mr. Joe Scollan  
 Bee & Jay Water Systems  
 P.O. Box 78 Route 6  
 Mahopac, NY 10541

Sample Information

Matrix: DRINKING WATER  
 Location Code: BEEJAYPVS  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: HW  
 Received by: B  
 Analyzed by: see "By" below

Date

09/27/16  
 09/27/16

Time

16:49

Laboratory Data

SDG ID: GBV29518  
 Phoenix ID: BV29541

Project ID: PUT VAL ELEM SCHOOL  
 Client ID: NEW WING GIRLS BATH RIGHT

| Parameter             | Result    | RL/<br>PQL | DIL | Units | AL    | MCL | MCLG | Date/Time | By      | Reference         |
|-----------------------|-----------|------------|-----|-------|-------|-----|------|-----------|---------|-------------------|
| Lead                  | 0.001     | 0.001      | 1   | mg/L  | 0.015 |     |      | 09/30/16  | MA/TH   | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed |            |     |       |       |     |      | 09/28/16  | /RVMAG/ | E200.9            |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 05, 2016**

**Reviewed and Released by: Deb Lawrie, Project Manager**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 October 05, 2016

FOR: Mr. Joe Scollan  
 Bee & Jay Water Systems  
 P.O. Box 78 Route 6  
 Mahopac, NY 10541

Sample Information

Matrix: DRINKING WATER  
 Location Code: BEEJAYPVS  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: HW  
 Received by: B  
 Analyzed by: see "By" below

Date

09/27/16  
 09/27/16

Time

16:49

Laboratory Data

SDG ID: GBV29518  
 Phoenix ID: BV29542

Project ID: PUT VAL ELEM SCHOOL  
 Client ID: 1117 BATH SINK

| Parameter  | Result    | RL/<br>PQL | DIL | Units | AL    | MCL | MCLG | Date/Time | By      | Reference         |
|--|-----------|------------|-----|-------|-------|-----|------|-----------|---------|-------------------|
| Lead   | 0.018     | 0.002      | 4   | mg/L  | 0.015 |     |      | 10/01/16  | MA/TH   | E200.9/SM3113B-10 |
| *** Lead is greater than or equal to Action Level of 0.015 *** |           |            |     |       |       |     |      |           |         |                   |
| Total Metal Digestion  | Completed |            |     |       |       |     |      | 09/28/16  | /RVM/AG | E200.9            |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 05, 2016**

**Reviewed and Released by: Deb Lawrie, Project Manager**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 05, 2016

FOR: Mr. Joe Scollan  
 Bee & Jay Water Systems  
 P.O. Box 78 Route 6  
 Mahopac, NY 10541

### Sample Information

Matrix: DRINKING WATER  
 Location Code: BEEJAYPVS  
 Rush Request: Standard  
 P.O.#:

### Custody Information

Collected by: HW  
 Received by: B  
 Analyzed by: see "By" below

### Date

09/27/16  
 09/27/16

### Time

16:49

## Laboratory Data

SDG ID: GBV29518  
 Phoenix ID: BV29543

Project ID: PUT VAL ELEM SCHOOL  
 Client ID: 1103 SINK

| Parameter             | Result    | RL/<br>PQL | DIL | Units | AL    | MCL | MCLG | Date/Time | By      | Reference         |
|-----------------------|-----------|------------|-----|-------|-------|-----|------|-----------|---------|-------------------|
| Lead                  | 0.007     | 0.001      | 1   | mg/L  | 0.015 |     |      | 10/01/16  | MA/TH   | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed |            |     |       |       |     |      | 09/28/16  | /RVMAG/ | E200.9            |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

### Comments:

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 05, 2016**

**Reviewed and Released by: Deb Lawrie, Project Manager**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 October 05, 2016

FOR: Mr. Joe Scollan  
 Bee & Jay Water Systems  
 P.O. Box 78 Route 6  
 Mahopac, NY 10541

Sample Information

Matrix: DRINKING WATER  
 Location Code: BEEJAYPVS  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: HW  
 Received by: B  
 Analyzed by: see "By" below

Date Time

09/27/16  
 09/27/16 16:49

Laboratory Data

SDG ID: GBV29518  
 Phoenix ID: BV29544

Project ID: PUT VAL ELEM SCHOOL  
 Client ID: 1115 BATH SINK

| Parameter             | Result    | RL/<br>PQL | DIL | Units | AL    | MCL | MCLG | Date/Time | By      | Reference         |
|-----------------------|-----------|------------|-----|-------|-------|-----|------|-----------|---------|-------------------|
| Lead                  | 0.010     | 0.001      | 1   | mg/L  | 0.015 |     |      | 10/01/16  | MA/TH   | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed |            |     |       |       |     |      | 09/28/16  | /RVMAG/ | E200.9            |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 05, 2016**

**Reviewed and Released by: Deb Lawrie, Project Manager**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 October 05, 2016

FOR: Mr. Joe Scollan  
 Bee & Jay Water Systems  
 P.O. Box 78 Route 6  
 Mahopac, NY 10541

Sample Information

Matrix: DRINKING WATER  
 Location Code: BEEJAYPVS  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: HW  
 Received by: B  
 Analyzed by: see "By" below

Date

09/27/16  
 09/27/16

Time

16:49

Laboratory Data

SDG ID: GBV29518  
 Phoenix ID: BV29545

Project ID: PUT VAL ELEM SCHOOL  
 Client ID: 1107 SINK

| Parameter  | Result    | RL/<br>PQL | DIL | Units | AL    | MCL | MCLG | Date/Time | By       | Reference         |
|--|-----------|------------|-----|-------|-------|-----|------|-----------|----------|-------------------|
| Lead   | 0.019     | 0.005      | 10  | mg/L  | 0.015 |     |      | 10/01/16  | MA/TH    | E200.9/SM3113B-10 |
| *** Lead is greater than or equal to Action Level of 0.015 *** |           |            |     |       |       |     |      |           |          |                   |
| Total Metal Digestion  | Completed |            |     |       |       |     |      | 09/28/16  | /RVM/AG/ | E200.9            |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 05, 2016**

**Reviewed and Released by: Deb Lawrie, Project Manager**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 October 05, 2016

FOR: Mr. Joe Scollan  
 Bee & Jay Water Systems  
 P.O. Box 78 Route 6  
 Mahopac, NY 10541

Sample Information

Matrix: DRINKING WATER  
 Location Code: BEEJAYPVS  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: HW  
 Received by: B  
 Analyzed by: see "By" below

Date                      Time  
 09/27/16  
 09/27/16                      16:49

Laboratory Data

SDG ID: GBV29518  
 Phoenix ID: BV29546

Project ID: PUT VAL ELEM SCHOOL  
 Client ID: 1103 FOUNTAIN

| Parameter             | Result    | RL/<br>PQL | DIL | Units | AL    | MCL | MCLG | Date/Time | By      | Reference         |
|-----------------------|-----------|------------|-----|-------|-------|-----|------|-----------|---------|-------------------|
| Lead                  | 0.009     | 0.005      | 10  | mg/L  | 0.015 |     |      | 10/01/16  | MA/TH   | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed |            |     |       |       |     |      | 09/28/16  | /RVMAG/ | E200.9            |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 05, 2016**

**Reviewed and Released by: Deb Lawrie, Project Manager**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 05, 2016

FOR: Mr. Joe Scollan  
 Bee & Jay Water Systems  
 P.O. Box 78 Route 6  
 Mahopac, NY 10541

Sample Information

Matrix: DRINKING WATER  
 Location Code: BEEJAYPVS  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: HW  
 Received by: B  
 Analyzed by: see "By" below

Date

09/27/16  
 09/27/16

Time

16:49

## Laboratory Data

SDG ID: GBV29518  
 Phoenix ID: BV29547

Project ID: PUT VAL ELEM SCHOOL  
 Client ID: 1115 FOUNTAIN

| Parameter             | Result    | RL/<br>PQL | DIL | Units | AL    | MCL | MCLG | Date/Time | By      | Reference         |
|-----------------------|-----------|------------|-----|-------|-------|-----|------|-----------|---------|-------------------|
| Lead                  | 0.008     | 0.001      | 1   | mg/L  | 0.015 |     |      | 10/01/16  | MA/TH   | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed |            |     |       |       |     |      | 09/28/16  | /RVMAG/ | E200.9            |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 05, 2016**

**Reviewed and Released by: Deb Lawrie, Project Manager**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 October 05, 2016

FOR: Mr. Joe Scollan  
 Bee & Jay Water Systems  
 P.O. Box 78 Route 6  
 Mahopac, NY 10541

Sample Information

Matrix: DRINKING WATER  
 Location Code: BEEJAYPVS  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: HW  
 Received by: B  
 Analyzed by: see "By" below

Date                      Time  
 09/27/16  
 09/27/16                      16:49

Laboratory Data

SDG ID: GBV29518  
 Phoenix ID: BV29548

Project ID: PUT VAL ELEM SCHOOL  
 Client ID: 1129 BATH SINK

| Parameter             | Result    | RL/<br>PQL | DIL | Units | AL    | MCL | MCLG | Date/Time | By      | Reference         |
|-----------------------|-----------|------------|-----|-------|-------|-----|------|-----------|---------|-------------------|
| Lead                  | 0.013     | 0.005      | 10  | mg/L  | 0.015 |     |      | 10/01/16  | MA/TH   | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed |            |     |       |       |     |      | 09/28/16  | /RVMAG/ | E200.9            |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 05, 2016**

**Reviewed and Released by: Deb Lawrie, Project Manager**





**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 05, 2016

FOR: Mr. Joe Scollan  
 Bee & Jay Water Systems  
 P.O. Box 78 Route 6  
 Mahopac, NY 10541

Sample Information

Matrix: DRINKING WATER  
 Location Code: BEEJAYPVS  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: HW  
 Received by: B  
 Analyzed by: see "By" below

Date

09/27/16  
 09/27/16

Time

16:49

## Laboratory Data

SDG ID: GBV29518  
 Phoenix ID: BV29549

Project ID: PUT VAL ELEM SCHOOL  
 Client ID: NEW WING GIRLS BATH LEFT

| Parameter             | Result    | RL/<br>PQL | DIL | Units | AL    | MCL | MCLG | Date/Time | By      | Reference         |
|-----------------------|-----------|------------|-----|-------|-------|-----|------|-----------|---------|-------------------|
| Lead                  | 0.008     | 0.001      | 1   | mg/L  | 0.015 |     |      | 10/01/16  | MA/TH   | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed |            |     |       |       |     |      | 09/28/16  | /RVMAG/ | E200.9            |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 05, 2016**

**Reviewed and Released by: Deb Lawrie, Project Manager**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 October 05, 2016

FOR: Mr. Joe Scollan  
 Bee & Jay Water Systems  
 P.O. Box 78 Route 6  
 Mahopac, NY 10541

Sample Information

Matrix: DRINKING WATER  
 Location Code: BEEJAYPVS  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: HW  
 Received by: B  
 Analyzed by: see "By" below

Date                      Time  
 09/27/16  
 09/27/16                      16:49

Laboratory Data

SDG ID: GBV29518  
 Phoenix ID: BV29550

Project ID: PUT VAL ELEM SCHOOL  
 Client ID: 3RD FLOOR HALLWAY FOUNTAIN

| Parameter             | Result    | RL/<br>PQL | DIL | Units | AL    | MCL | MCLG | Date/Time | By      | Reference         |
|-----------------------|-----------|------------|-----|-------|-------|-----|------|-----------|---------|-------------------|
| Lead                  | 0.002     | 0.001      | 1   | mg/L  | 0.015 |     |      | 10/01/16  | MA/TH   | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed |            |     |       |       |     |      | 09/28/16  | /RVMAG/ | E200.9            |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 05, 2016**

**Reviewed and Released by: Deb Lawrie, Project Manager**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 October 05, 2016

FOR: Mr. Joe Scollan  
 Bee & Jay Water Systems  
 P.O. Box 78 Route 6  
 Mahopac, NY 10541

Sample Information

Matrix: DRINKING WATER  
 Location Code: BEEJAYPVS  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: HW  
 Received by: B  
 Analyzed by: see "By" below

Date                      Time  
 09/27/16  
 09/27/16                      16:49

Laboratory Data

SDG ID: GBV29518  
 Phoenix ID: BV29551

Project ID: PUT VAL ELEM SCHOOL  
 Client ID: NEW WING FOUNTAIN SHORT

| Parameter             | Result    | RL/<br>PQL | DIL | Units | AL    | MCL | MCLG | Date/Time | By      | Reference         |
|-----------------------|-----------|------------|-----|-------|-------|-----|------|-----------|---------|-------------------|
| Lead                  | 0.001     | 0.001      | 1   | mg/L  | 0.015 |     |      | 10/01/16  | MA/TH   | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed |            |     |       |       |     |      | 09/28/16  | /RVMAG/ | E200.9            |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 05, 2016**

**Reviewed and Released by: Deb Lawrie, Project Manager**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 October 05, 2016

FOR: Mr. Joe Scollan  
 Bee & Jay Water Systems  
 P.O. Box 78 Route 6  
 Mahopac, NY 10541

Sample Information

Matrix: DRINKING WATER  
 Location Code: BEEJAYPVS  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: HW  
 Received by: B  
 Analyzed by: see "By" below

Date Time

09/27/16  
 09/27/16 16:49

Laboratory Data

SDG ID: GBV29518  
 Phoenix ID: BV29552

Project ID: PUT VAL ELEM SCHOOL  
 Client ID: 1097 BATH SINK

| Parameter  | Result    | RL/<br>PQL | DIL | Units | AL    | MCL | MCLG | Date/Time | By             | Reference         |
|--|-----------|------------|-----|-------|-------|-----|------|-----------|----------------|-------------------|
| Lead   | 0.015     | 0.001      | 1   | mg/L  | 0.015 |     |      | 10/02/16  | TH             | E200.9/SM3113B-10 |
| *** Lead is greater than or equal to Action Level of 0.015 *** |           |            |     |       |       |     |      |           |                |                   |
| Total Metal Digestion  | Completed |            |     |       |       |     |      | 09/28/16  | /RVM/AG/E200.9 |                   |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 05, 2016**

**Reviewed and Released by: Deb Lawrie, Project Manager**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 October 05, 2016

FOR: Mr. Joe Scollan  
 Bee & Jay Water Systems  
 P.O. Box 78 Route 6  
 Mahopac, NY 10541

Sample Information

Matrix: DRINKING WATER  
 Location Code: BEEJAYPVS  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: HW  
 Received by: B  
 Analyzed by: see "By" below

Date                      Time  
 09/27/16  
 09/27/16                      16:49

Laboratory Data

SDG ID: GBV29518  
 Phoenix ID: BV29553

Project ID: PUT VAL ELEM SCHOOL  
 Client ID: LIBRARY SINK

| Parameter             | Result    | RL/<br>PQL | DIL | Units | AL    | MCL | MCLG | Date/Time | By            | Reference         |
|-----------------------|-----------|------------|-----|-------|-------|-----|------|-----------|---------------|-------------------|
| Lead                  | 0.006     | 0.001      | 1   | mg/L  | 0.015 |     |      | 10/02/16  | TH            | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed |            |     |       |       |     |      | 09/28/16  | /RVMAG/E200.9 |                   |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 05, 2016**

**Reviewed and Released by: Deb Lawrie, Project Manager**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 October 05, 2016

FOR: Mr. Joe Scollan  
 Bee & Jay Water Systems  
 P.O. Box 78 Route 6  
 Mahopac, NY 10541

Sample Information

Matrix: DRINKING WATER  
 Location Code: BEEJAYPVS  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: HW  
 Received by: B  
 Analyzed by: see "By" below

Date

09/27/16  
 09/27/16

Time

16:49

Laboratory Data

SDG ID: GBV29518  
 Phoenix ID: BV29554

Project ID: PUT VAL ELEM SCHOOL  
 Client ID: 1126 FOUNTAIN

| Parameter             | Result    | RL/<br>PQL | DIL | Units | AL    | MCL | MCLG | Date/Time | By            | Reference         |
|-----------------------|-----------|------------|-----|-------|-------|-----|------|-----------|---------------|-------------------|
| Lead                  | 0.006     | 0.001      | 1   | mg/L  | 0.015 |     |      | 10/02/16  | TH            | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed |            |     |       |       |     |      | 09/28/16  | /RVMAG/E200.9 |                   |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 05, 2016**

**Reviewed and Released by: Deb Lawrie, Project Manager**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 October 05, 2016

FOR: Mr. Joe Scollan  
 Bee & Jay Water Systems  
 P.O. Box 78 Route 6  
 Mahopac, NY 10541

Sample Information

Matrix: DRINKING WATER  
 Location Code: BEEJAYPVS  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: HW  
 Received by: B  
 Analyzed by: see "By" below

Date                      Time  
 09/27/16  
 09/27/16                      16:49

Laboratory Data

SDG ID: GBV29518  
 Phoenix ID: BV29555

Project ID: PUT VAL ELEM SCHOOL  
 Client ID: 1126 SINK

| Parameter             | Result    | RL/<br>PQL | DIL | Units | AL    | MCL | MCLG | Date/Time | By            | Reference         |
|-----------------------|-----------|------------|-----|-------|-------|-----|------|-----------|---------------|-------------------|
| Lead                  | 0.009     | 0.001      | 1   | mg/L  | 0.015 |     |      | 10/02/16  | TH            | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed |            |     |       |       |     |      | 09/28/16  | /RVMAG/E200.9 |                   |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 05, 2016**

**Reviewed and Released by: Deb Lawrie, Project Manager**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 October 05, 2016

FOR: Mr. Joe Scollan  
 Bee & Jay Water Systems  
 P.O. Box 78 Route 6  
 Mahopac, NY 10541

Sample Information

Matrix: DRINKING WATER  
 Location Code: BEEJAYPVS  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: HW  
 Received by: B  
 Analyzed by: see "By" below

Date                      Time  
 09/27/16  
 09/27/16                      16:49

Laboratory Data

SDG ID: GBV29518  
 Phoenix ID: BV29556

Project ID: PUT VAL ELEM SCHOOL  
 Client ID: MAIN OFFICE BATH SINK

| Parameter             | Result    | RL/<br>PQL | DIL | Units | AL    | MCL | MCLG | Date/Time | By            | Reference         |
|-----------------------|-----------|------------|-----|-------|-------|-----|------|-----------|---------------|-------------------|
| Lead                  | 0.008     | 0.001      | 1   | mg/L  | 0.015 |     |      | 10/02/16  | TH            | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed |            |     |       |       |     |      | 09/28/16  | /RVMAG/E200.9 |                   |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 05, 2016**

**Reviewed and Released by: Deb Lawrie, Project Manager**





**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 October 05, 2016

FOR: Mr. Joe Scollan  
 Bee & Jay Water Systems  
 P.O. Box 78 Route 6  
 Mahopac, NY 10541

Sample Information

Matrix: DRINKING WATER  
 Location Code: BEEJAYPVS  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: HW  
 Received by: B  
 Analyzed by: see "By" below

Date

09/27/16  
 09/27/16

Time

16:49

Laboratory Data

SDG ID: GBV29518  
 Phoenix ID: BV29557

Project ID: PUT VAL ELEM SCHOOL  
 Client ID: 1ST GRADE BATH SINK

| Parameter             | Result    | RL/<br>PQL | DIL | Units | AL    | MCL | MCLG | Date/Time | By      | Reference         |
|-----------------------|-----------|------------|-----|-------|-------|-----|------|-----------|---------|-------------------|
| Lead                  | 0.004     | 0.001      | 1   | mg/L  | 0.015 |     |      | 10/01/16  | MA/TH   | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed |            |     |       |       |     |      | 09/28/16  | /RVMAG/ | E200.9            |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 05, 2016**

**Reviewed and Released by: Deb Lawrie, Project Manager**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 05, 2016

FOR: Mr. Joe Scollan  
 Bee & Jay Water Systems  
 P.O. Box 78 Route 6  
 Mahopac, NY 10541

Sample Information

Matrix: DRINKING WATER  
 Location Code: BEEJAYPVS  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: HW  
 Received by: B  
 Analyzed by: see "By" below

Date

09/27/16  
 09/27/16

Time

16:49

## Laboratory Data

SDG ID: GBV29518  
 Phoenix ID: BV29558

Project ID: PUT VAL ELEM SCHOOL  
 Client ID: CAFETERIA FOUNTAIN

| Parameter             | Result    | RL/<br>PQL | DIL | Units | AL    | MCL | MCLG | Date/Time | By      | Reference         |
|-----------------------|-----------|------------|-----|-------|-------|-----|------|-----------|---------|-------------------|
| Lead                  | 0.014     | 0.001      | 1   | mg/L  | 0.015 |     |      | 10/01/16  | MA/TH   | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed |            |     |       |       |     |      | 09/28/16  | /RVMAG/ | E200.9            |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 05, 2016**

**Reviewed and Released by: Deb Lawrie, Project Manager**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 October 05, 2016

FOR: Mr. Joe Scollan  
 Bee & Jay Water Systems  
 P.O. Box 78 Route 6  
 Mahopac, NY 10541

Sample Information

Matrix: DRINKING WATER  
 Location Code: BEEJAYPVS  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: HW  
 Received by: B  
 Analyzed by: see "By" below

Date

09/27/16  
 09/27/16

Time

16:49

Laboratory Data

SDG ID: GBV29518  
 Phoenix ID: BV29559

Project ID: PUT VAL ELEM SCHOOL  
 Client ID: MAIN HALL STUDENT BATH

| Parameter             | Result    | RL/<br>PQL | DIL | Units | AL    | MCL | MCLG | Date/Time | By      | Reference         |
|-----------------------|-----------|------------|-----|-------|-------|-----|------|-----------|---------|-------------------|
| Lead                  | 0.004     | 0.001      | 1   | mg/L  | 0.015 |     |      | 10/01/16  | MA/TH   | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed |            |     |       |       |     |      | 09/28/16  | /RVMAG/ | E200.9            |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 05, 2016**

**Reviewed and Released by: Deb Lawrie, Project Manager**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 October 05, 2016

FOR: Mr. Joe Scollan  
 Bee & Jay Water Systems  
 P.O. Box 78 Route 6  
 Mahopac, NY 10541

Sample Information

Matrix: DRINKING WATER  
 Location Code: BEEJAYPVS  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: HW  
 Received by: B  
 Analyzed by: see "By" below

Date                      Time  
 09/27/16  
 09/27/16                      16:49

Laboratory Data

SDG ID: GBV29518  
 Phoenix ID: BV29560

Project ID: PUT VAL ELEM SCHOOL  
 Client ID: ART ROOM SINK

| Parameter             | Result    | RL/<br>PQL | DIL | Units | AL    | MCL | MCLG | Date/Time | By            | Reference         |
|-----------------------|-----------|------------|-----|-------|-------|-----|------|-----------|---------------|-------------------|
| Lead                  | 0.003     | 0.001      | 1   | mg/L  | 0.015 |     |      | 10/02/16  | TH            | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed |            |     |       |       |     |      | 09/28/16  | /RVMAG/E200.9 |                   |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 05, 2016**

**Reviewed and Released by: Deb Lawrie, Project Manager**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 October 05, 2016

FOR: Mr. Joe Scollan  
 Bee & Jay Water Systems  
 P.O. Box 78 Route 6  
 Mahopac, NY 10541

Sample Information

Matrix: DRINKING WATER  
 Location Code: BEEJAYPVS  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: HW  
 Received by: B  
 Analyzed by: see "By" below

Date                      Time  
 09/27/16  
 09/27/16                      16:49

Laboratory Data

SDG ID: GBV29518  
 Phoenix ID: BV29561

Project ID: PUT VAL ELEM SCHOOL  
 Client ID: 1123 BATH SINK

| Parameter             | Result    | RL/<br>PQL | DIL | Units | AL    | MCL | MCLG | Date/Time | By            | Reference         |
|-----------------------|-----------|------------|-----|-------|-------|-----|------|-----------|---------------|-------------------|
| Lead                  | 0.011     | 0.002      | 4   | mg/L  | 0.015 |     |      | 10/03/16  | RS            | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed |            |     |       |       |     |      | 09/28/16  | /RVMAG/E200.9 |                   |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 05, 2016**

**Reviewed and Released by: Deb Lawrie, Project Manager**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 October 05, 2016

FOR: Mr. Joe Scollan  
 Bee & Jay Water Systems  
 P.O. Box 78 Route 6  
 Mahopac, NY 10541

Sample Information

Matrix: DRINKING WATER  
 Location Code: BEEJAYPVS  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: HW  
 Received by: B  
 Analyzed by: see "By" below

Date Time

09/27/16  
 09/27/16 16:49

Laboratory Data

SDG ID: GBV29518  
 Phoenix ID: BV29562

Project ID: PUT VAL ELEM SCHOOL  
 Client ID: 1107 FOUNTAIN

| Parameter             | Result    | RL/<br>PQL | DIL | Units | AL    | MCL | MCLG | Date/Time | By      | Reference         |
|-----------------------|-----------|------------|-----|-------|-------|-----|------|-----------|---------|-------------------|
| Lead                  | 0.005     | 0.001      | 1   | mg/L  | 0.015 |     |      | 10/01/16  | MA/TH   | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed |            |     |       |       |     |      | 09/28/16  | /RVMAG/ | E200.9            |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 05, 2016**

**Reviewed and Released by: Deb Lawrie, Project Manager**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

**Analysis Report**  
 October 05, 2016

FOR: Mr. Joe Scollan  
 Bee & Jay Water Systems  
 P.O. Box 78 Route 6  
 Mahopac, NY 10541

Sample Information

Matrix: DRINKING WATER  
 Location Code: BEEJAYPVS  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: HW  
 Received by: B  
 Analyzed by: see "By" below

Date                      Time  
 09/27/16  
 09/27/16                      16:49

Laboratory Data

SDG ID: GBV29518  
 Phoenix ID: BV29563

Project ID: PUT VAL ELEM SCHOOL  
 Client ID: 1115 SINK

| Parameter             | Result    | RL/<br>PQL | DIL | Units | AL    | MCL | MCLG | Date/Time | By            | Reference         |
|-----------------------|-----------|------------|-----|-------|-------|-----|------|-----------|---------------|-------------------|
| Lead                  | < 0.001   | 0.001      | 1   | mg/L  | 0.015 |     |      | 10/03/16  | RS            | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed |            |     |       |       |     |      | 09/28/16  | /RVMAG/E200.9 |                   |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 05, 2016**

**Reviewed and Released by: Deb Lawrie, Project Manager**



**Environmental Laboratories, Inc.**  
 587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823

# Analysis Report

October 05, 2016

FOR: Mr. Joe Scollan  
 Bee & Jay Water Systems  
 P.O. Box 78 Route 6  
 Mahopac, NY 10541

Sample Information

Matrix: DRINKING WATER  
 Location Code: BEEJAYPVS  
 Rush Request: Standard  
 P.O.#:

Custody Information

Collected by: HW  
 Received by: B  
 Analyzed by: see "By" below

Date

09/27/16  
 09/27/16

Time

16:49

## Laboratory Data

SDG ID: GBV29518  
 Phoenix ID: BV29564

Project ID: PUT VAL ELEM SCHOOL  
 Client ID: 1123 SINK

| Parameter             | Result    | RL/<br>PQL | DIL | Units | AL    | MCL | MCLG | Date/Time | By   | Reference         |
|-----------------------|-----------|------------|-----|-------|-------|-----|------|-----------|------|-------------------|
| Lead                  | 0.011     | 0.002      | 4   | mg/L  | 0.015 |     |      | 10/03/16  | RS   | E200.9/SM3113B-10 |
| Total Metal Digestion | Completed |            |     |       |       |     |      | 09/29/16  | T/GL | E200.9            |

RL/PQL=Reporting/Practical Quantitation Level DIL=Dilution (analysis required diluting to evaluate) ND=Not Detected  
 BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.)  
 AL = Action Level MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

**Comments:**

Maximum Contaminant Level (MCL) (Lower of): 40 CFR Part 141; Public Health Law, Section 225 Part 5. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Action Level (AL): (Lower of): 40 CFR Part 141.80; Public Health Law, Section 225 Part 5.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 141; 40 CFR Part 143. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.  
 This report must not be reproduced except in full as defined by the attached chain of custody.

**Phyllis Shiller, Laboratory Director**

**October 05, 2016**

**Reviewed and Released by: Deb Lawrie, Project Manager**





Environmental Laboratories, Inc.  
 587 East Middle Turnpike, P.O. Box 370, Manchester, CT 06045  
 Tel. (860) 645-1102 Fax (860) 645-0823



# QA/QC Report

October 05, 2016

## QA/QC Data

SDG I.D.: GBV29518

| Parameter  | Blank | Blk RL | Sample Result | Dup Result | Dup RPD | LCS % | LCSD % | LCS RPD | MS % | MSD % | MS RPD | % Rec Limits | % RPD Limits |
|--|-------|--------|---------------|------------|---------|-------|--------|---------|------|-------|--------|--------------|--------------|
| QA/QC Batch 360554A (mg/L), QC Sample No: BV29447 (BV29518, BV29519, BV29520, BV29521, BV29522, BV29523)                                     |       |        |               |            |         |       |        |         |      |       |        |              |              |
| Lead   | BRL   | 0.001  |               |            |         | 96.9  |        |         | 97.8 |       |        | 85 - 115     | 20           |
| Comment:<br>This batch does not include a duplicate.   |       |        |               |            |         |       |        |         |      |       |        |              |              |
| Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%.   |       |        |               |            |         |       |        |         |      |       |        |              |              |
| QA/QC Batch 360647 (mg/L), QC Sample No: BV29495 (BV29564)   |       |        |               |            |         |       |        |         |      |       |        |              |              |
| Lead   | BRL   | 0.001  | 0.004         | 0.004      | NC      | 101   |        |         | 94.2 |       |        | 85 - 115     | 20           |
| Comment:<br>Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%.   |       |        |               |            |         |       |        |         |      |       |        |              |              |
| QA/QC Batch 360555 (mg/L), QC Sample No: BV29524 (BV29524, BV29525, BV29526, BV29527, BV29528, BV29529, BV29530, BV29531, BV29532, BV29533)  |       |        |               |            |         |       |        |         |      |       |        |              |              |
| Lead   | BRL   | 0.001  | 0.005         | 0.004      | NC      | 104   |        |         |      |       |        | 85 - 115     | 20           |
| Comment:<br>Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%.   |       |        |               |            |         |       |        |         |      |       |        |              |              |
| QA/QC Batch 360555A (mg/L), QC Sample No: BV29534 (BV29534, BV29535, BV29536, BV29537, BV29538, BV29539, BV29540, BV29541, BV29542, BV29543) |       |        |               |            |         |       |        |         |      |       |        |              |              |
| Lead   | BRL   | 0.001  |               |            |         | 104   |        |         | 75.6 |       |        | 85 - 115     | 20           |
| Comment:<br>This batch does not include a duplicate.   |       |        |               |            |         |       |        |         |      |       |        |              |              |
| Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%.   |       |        |               |            |         |       |        |         |      |       |        |              |              |
| QA/QC Batch 360556 (mg/L), QC Sample No: BV29544 (BV29544, BV29545, BV29546, BV29547, BV29548, BV29549, BV29550, BV29551, BV29552, BV29553)  |       |        |               |            |         |       |        |         |      |       |        |              |              |
| Lead   | BRL   | 0.001  | 0.010         | 0.006      | 50.0    | 96.7  |        |         | 114  |       |        | 85 - 115     | 20           |
| Comment:<br>Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%.   |       |        |               |            |         |       |        |         |      |       |        |              |              |
| QA/QC Batch 360556A (mg/L), QC Sample No: BV29554 (BV29554, BV29555, BV29556, BV29557, BV29558, BV29559, BV29560, BV29561, BV29562, BV29563) |       |        |               |            |         |       |        |         |      |       |        |              |              |
| Lead   | BRL   | 0.001  |               |            |         | 96.7  |        |         | 79.7 |       |        | 85 - 115     | 20           |
| Comment:<br>This batch does not include a duplicate.   |       |        |               |            |         |       |        |         |      |       |        |              |              |
| Additional: LCS acceptance range is 85-115% MS acceptance range 75-125%.   |       |        |               |            |         |       |        |         |      |       |        |              |              |

r = This parameter is outside laboratory RPD specified recovery limits.

# QA/QC Data


SDG I.D.: GBV29518

| Parameter | Blank | Blk<br>RL | Sample<br>Result | Dup<br>Result | Dup<br>RPD | LCS<br>% | LCSD<br>% | LCS<br>RPD | MS<br>% | MSD<br>% | MS<br>RPD | %<br>Rec<br>Limits | %<br>RPD<br>Limits |
|-----------|-------|-----------|------------------|---------------|------------|----------|-----------|------------|---------|----------|-----------|--------------------|--------------------|
|-----------|-------|-----------|------------------|---------------|------------|----------|-----------|------------|---------|----------|-----------|--------------------|--------------------|

---

If there are any questions regarding this data, please call Phoenix Client Services at extension 200.

- RPD - Relative Percent Difference
- LCS - Laboratory Control Sample
- LCSD - Laboratory Control Sample Duplicate
- MS - Matrix Spike
- MS Dup - Matrix Spike Duplicate
- NC - No Criteria
- Intf - Interference



Phyllis Shiller, Laboratory Director  
October 05, 2016

## Sample Criteria Exceedences Report

### GBV29518 - BEEJAYPVS

Criteria: None

State: NY

| SampNo  | Acode | Phoenix Analyte | Criteria                                       | Result | RL    | Criteria | RL<br>Criteria | Analysis<br>Units |
|---------|-------|-----------------|--|--------|-------|----------|----------------|-------------------|
| BV29518 | PB-DW | Lead            | EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs | 0.015  | 0.002 | 0.015    | 0.001          | mg/L              |
| BV29518 | PB-DW | Lead            | NY / NY Residential DW / Lead & Copper Als     | 0.015  | 0.002 | 0.015    | 0.015          | mg/L              |
| BV29523 | PB-DW | Lead            | EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs | 0.022  | 0.002 | 0.015    | 0.001          | mg/L              |
| BV29523 | PB-DW | Lead            | NY / NY Residential DW / Lead & Copper Als     | 0.022  | 0.002 | 0.015    | 0.015          | mg/L              |
| BV29533 | PB-DW | Lead            | EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs | 0.231  | 0.005 | 0.015    | 0.001          | mg/L              |
| BV29533 | PB-DW | Lead            | NY / NY Residential DW / Lead & Copper Als     | 0.231  | 0.005 | 0.015    | 0.015          | mg/L              |
| BV29538 | PB-DW | Lead            | EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs | 0.025  | 0.002 | 0.015    | 0.001          | mg/L              |
| BV29538 | PB-DW | Lead            | NY / NY Residential DW / Lead & Copper Als     | 0.025  | 0.002 | 0.015    | 0.015          | mg/L              |
| BV29540 | PB-DW | Lead            | EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs | 0.053  | 0.002 | 0.015    | 0.001          | mg/L              |
| BV29540 | PB-DW | Lead            | NY / NY Residential DW / Lead & Copper Als     | 0.053  | 0.002 | 0.015    | 0.015          | mg/L              |
| BV29542 | PB-DW | Lead            | EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs | 0.018  | 0.002 | 0.015    | 0.001          | mg/L              |
| BV29542 | PB-DW | Lead            | NY / NY Residential DW / Lead & Copper Als     | 0.018  | 0.002 | 0.015    | 0.015          | mg/L              |
| BV29545 | PB-DW | Lead            | EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs | 0.019  | 0.005 | 0.015    | 0.001          | mg/L              |
| BV29545 | PB-DW | Lead            | NY / NY Residential DW / Lead & Copper Als     | 0.019  | 0.005 | 0.015    | 0.015          | mg/L              |
| BV29552 | PB-DW | Lead            | EPA / 40 CFR 141 DW / 141.80 Lead & Copper ALs | 0.015  | 0.001 | 0.015    | 0.001          | mg/L              |
| BV29552 | PB-DW | Lead            | NY / NY Residential DW / Lead & Copper Als     | 0.015  | 0.001 | 0.015    | 0.015          | mg/L              |

Phoenix Laboratories does not assume responsibility for the data contained in this report. It is provided as an additional tool to identify requested criteria exceedences. All efforts are made to ensure the accuracy of the data (obtained from appropriate agencies). A lack of exceedence information does not necessarily suggest conformance to the criteria. It is ultimately the site professional's responsibility to determine appropriate compliance.



**Environmental Laboratories, Inc.**  
587 East Middle Turnpike, P.O.Box 370, Manchester, CT 06045  
Tel. (860) 645-1102 Fax (860) 645-0823



# NY Temperature Narration

October 05, 2016

SDG I.D.: GBV29518

---

The samples in this delivery group were received at 4°C.  
(Note acceptance criteria is above freezing up to 6°C)



NY/NJ CHAIN OF CUSTODY RECORD



587 East Middle Turnpike, P.O. Box 370, Manchester, CT 06040  
 Email: info@phoenixlabs.com Fax (860) 645-0823

Client Services (860) 645-8726

Data Delivery:  
 Fax #:  
 Email: joe@beeandjayplumbing.com

Customer: Bee & Jay Water Systems  
 Address: P.O. Box 76, Route 6 Mahopac, NY 10541  
 Project: PUTNAM VALLEY SCHOOL  
 Report to: Joseph Scollan  
 Invoice to:  
 Project P.O.:  
 Phone #: 845-628-3924  
 Fax #: 845-628-4062

Client Sample - Information - Identification

Sampler's Signature: *Murray Wilson* Date: 9/22/16

MATRIX CODE:  
 DW=drinking water S=soil/solid O=oil  
 GW=groundwater SL=sludge A=air X=other

| Phoenix Sample # | Customer Sample Identification | Sample Matrix | Date Sampled | Time Sampled | Analysis Request |
|------------------|--------------------------------|---------------|--------------|--------------|------------------|
| 29530            | 1107 BATH SINK                 |               |              |              |                  |
| 29531            | 1107 BATH SINK                 |               |              |              |                  |
| 29532            | 1097 SINK                      |               |              |              |                  |
| 29533            | 1097 SINK                      |               |              |              |                  |
| 29534            | 1117 FOUNTAIN                  |               |              |              |                  |
| 29535            | 1117 SINK                      |               |              |              |                  |
| 29536            | 3RD FLOOR FACULTY BATH         |               | 9/22         | 1ST DRAW     |                  |
| 29537            | NEW WING FACULTY BATH          |               |              |              |                  |
| 29538            | 1126 BATH SINK                 |               |              |              |                  |
| 29539            | MAIN HALL FOUNTAIN             |               |              |              |                  |
| 29540            | 3004 SINK                      |               |              |              |                  |
| 29541            | NEW WING STALL BATH RIGHT      |               |              |              |                  |

| Relinquished by:   | Accepted by:       | Date:   | Time: |
|--------------------|--------------------|---------|-------|
| <i>[Signature]</i> | <i>[Signature]</i> | 9/22/16 | 14    |
| <i>[Signature]</i> | <i>[Signature]</i> | 9/22/16 | 15:15 |
| <i>[Signature]</i> | <i>[Signature]</i> | 9/22/16 | 16:45 |

Comments: Special Requirements or Regulations:  
 Turnaround:  
 1 Day\*  
 2 Days\*  
 3 Days\* Day\*  
 5 Days  
 10 Days  
 Other  
 \* SURCHARGE APPLIES  
 NY  
 TAGM 4046 GW  
 TAGM 4046 SOIL  
 NY375 Unrestricted Soil  
 NY375 Residential Soil  
 NY375 Restricted Non-Residential Soil  
 NJ  
 Res. Criteria  
 Non-Res. Criteria  
 Impact to GW Soil Cleanup Criteria  
 GW Criteria  
 Data Format  
 Phoenix Std Report  
 Excel  
 PDF  
 GIS/Key  
 EQUIS  
 NJ Hazsite EDD  
 NY EZ EDD (ASP)  
 Other  
 Data Package  
 NJ Reduced Deliv. \*  
 NY Enhanced (ASP B) \*  
 Other  
 State where samples were collected: NY

Putnam Valley School District  
 173 Oscawana Lake Road  
 Putnam Valley, NY 10579

NY/NJ CHAIN OF CUSTODY RECORD



587 East Middle Turnpike, P.O. Box 370, Manchester, CT 06040  
 Email: info@phoenixlabs.com Fax (860) 645-0823

Client Services (860) 645-8726

Temp 40.1 Pg 3 of 7

Data Delivery:  Fax #   Email: joe@beeandjayplumbing.com

Customer: Bee & Jay Water Systems Project P.O.: PUT VAL ELEM SCHOOL  
 Address: P.O. Box 78, Route 6 Report to: Joseph Scollan Phone #: 845-628-3924  
Mahopac, NY 10541 Invoice to: Phone #: 845-628-4062

| Phoenix Sample # | Customer Sample Identification | Sample Matrix | Date Sampled | Time Sampled | Analysis Request | Turnaround:  | NJ  | NY  | Data Format   |
|------------------|--------------------------------|---------------|--------------|--------------|------------------|--|---|---|---|
| 29542            | 1117 BATH SINK                 | OW            | 9/27/16      |              | LEAD             | <input type="checkbox"/> 1 Day*<br><input type="checkbox"/> 2 Days*<br><input type="checkbox"/> 3 Days* Day*<br><input type="checkbox"/> 5 Days<br><input type="checkbox"/> 0 Days<br><input type="checkbox"/> Other | <input type="checkbox"/> Res. Criteria<br><input type="checkbox"/> Non-Res. Criteria<br><input type="checkbox"/> Impact to GW Soil Cleanup Criteria<br><input type="checkbox"/> GW Criteria | <input type="checkbox"/> TAGM 4046 GW<br><input type="checkbox"/> TAGM 4046 SOIL<br><input type="checkbox"/> NY375 Unrestricted Soil<br><input type="checkbox"/> NY375 Residential Soil<br><input type="checkbox"/> NY375 Restricted Non-Residential Soil | <input type="checkbox"/> Phoenix Std Report<br><input type="checkbox"/> Excel<br><input type="checkbox"/> PDF<br><input type="checkbox"/> GIS/Key<br><input type="checkbox"/> EQiS<br><input type="checkbox"/> NJ Hazsite EDD<br><input type="checkbox"/> NY EZ EDD (ASP)<br><input type="checkbox"/> Other |
| 29543            | 1103 SINK                      | OW            | 9/27/16      |              | LEAD             |  |   |   |   |
| 29544            | 1115 BATH SINK                 | OW            | 9/27/16      |              | LEAD             |  |   |   |   |
| 29545            | 1107 SINK                      | OW            | 9/27/16      |              | LEAD             |  |   |   |   |
| 29546            | 1103 FOUNTAIN                  | OW            | 9/27/16      |              | LEAD             |  |   |   |   |
| 29547            | 1115 FOUNTAIN                  | OW            | 9/27/16      |              | LEAD             |  |   |   |   |
| 29548            | 1129 BATH SINK                 | OW            | 9/27/16      |              | LEAD             |  |   |   |   |
| 29549            | NEW WINE BAR                   | OW            | 9/27/16      |              | LEAD             |  |   |   |   |
| 29550            | 3RD FLOOR HALLWAY              | OW            | 9/27/16      |              | LEAD             |  |   |   |   |
| 29551            | NEW WINE FOUNTAIN              | OW            | 9/27/16      |              | LEAD             |  |   |   |   |
| 29552            | 1097 BATH SINK                 | OW            | 9/27/16      |              | LEAD             |  |   |   |   |

Putnam Valley School District  
 173 Oscawana Lake Road  
 Putnam Valley, NY 10579

State where samples were collected: NY

Comments, Special Requirements or Regulations:

Relinquished by: [Signature] Date: 9/27/16 Time: 11:00  
 Accepted by: [Signature] Date: 9/27/16 Time: 15:15

