

YML ENVIRONMENTAL SERVICES  
321 Kear Street  
Yorktown Heights, N.Y. 10598  
(914) 245-2800  
Albert H. Padovani, Director  
\*\* TEST REPORT \*\*

LAB #: 1.003663 CLIENT #: 551 NON STAT PROC PAGE: 1 of 1

PUTNAM VALLEY CENTRAL  
146 PEEKSKILL HOLLOW RD  
ATTN: DAVID SPITTAL  
PUTNAM VALLEY, NY 10579

DATE/TIME TAKEN: 10/24/20 10:07A  
DATE/TIME REC'D: 10/26/20 11:40A  
REPORT DATE: 11/06/20  
PHONE: (845)-526-7854

SAMPLING SITE: PUTNAM VALLEY SCHOOL DISTRICT  
: ADMIN BLDG KITCHEN SINK

SAMPLE TYPE...: POTABLE  
PRESERVATIVES: HNO3  
TEMP RECEIVED: 20C NOT ON ICE  
COLIFORM METH: N/A

COL'D BY: CAREY CLERICI  
NOTES...:

START DATE/TIME	END DATE/TIME	FLAG	PROCEDURE	RESULT	NORMAL - RANGE	METHOD
10/30/20			LEAD (IMS)	1.9 ppb	0-15 ppb	SM 22 3113B


COMMENTS:

Pb/Cu LEAD limits for public schools are set at 15 ppb.  
EPA Lead & Copper Rule for Public Systems requires that no more than 10% of their distribution points have a LEAD value of more than 15 ppb and a COPPER value of 1.3 mg/L, else water treatment must be undertaken to reduce the waters corrosive potential.

NRR 'NORMAL-RANGE' REFERENCE=  
U.S. ENVIRONMENTAL PROTECTION AGENCY (EPA); MAY 2009  
NATIONAL PRIMARY DRINKING WATER REGULATIONS  
VISIT: <https://www.epa.gov/ground-water-and-drinking-water/national-primary-drinking-water-regulation-table>

IMS IMS = IMMEDIATE METAL SAMPLE.  
(INTERPRETATION: WATER SAMPLED AFTER SITTING UNDISTURBED  
A MINIMUM OF 6 HOURS OR OVERNIGHT)

THE ABOVE TEST PROCEDURES MEET ALL REQUIREMENTS OF NELAC,  
AND RELATE ONLY TO THESE SAMPLES RECEIVED BY THE LAB

SUBMITTED BY:   
Albert H. Padovani, M.T. (ASCP)  
Director

ELAP# 10323

YML ENVIRONMENTAL SERVICES  
321 Kear Street  
Yorktown Heights, N.Y. 10598  
(914) 245-2800  
Albert H. Padovani, Director  
\*\* TEST REPORT \*\*

LAB #: 1.003664 CLIENT #: 551 NON STAT PROC PAGE: 1 of 1

PUTNAM VALLEY CENTRAL  
146 PEEKSKILL HOLLOW RD  
ATTN: DAVID SPITTAL  
PUTNAM VALLEY, NY 10579

DATE/TIME TAKEN: 10/24/20 10:07A  
DATE/TIME REC'D: 10/26/20 11:40A  
REPORT DATE: 11/06/20  
PHONE: (845)-526-7854

SAMPLING SITE: PUTNAM VALLEY SCHOOL DISTRICT  
: ADMIN BLDG SHOP SINK

SAMPLE TYPE.: POTABLE  
PRESERVATIVES: HNO3  
TEMP RECEIVED: 20C NOT ON ICE  
COLIFORM METH: N/A

COL'D BY: CAREY CLERICI  
NOTES....:

START DATE/TIME	END DATE/TIME	FLAG	PROCEDURE	RESULT	NORMAL - RANGE	METHOD
10/30/20			LEAD (IMS)	2.3 ppb	0-15 ppb	SM 22 3113B

COMMENTS:

Pb/Cu LEAD limits for public schools are set at 15 ppb.  
EPA Lead & Copper Rule for Public Systems requires that no more than 10% of their distribution points have a LEAD value of more than 15 ppb and a COPPER value of 1.3 mg/L, else water treatment must be undertaken to reduce the waters corrosive potential.

NRR 'NORMAL-RANGE' REFERENCE=  
U.S. ENVIRONMENTAL PROTECTION AGENCY (EPA); MAY 2009  
NATIONAL PRIMARY DRINKING WATER REGULATIONS  
VISIT: <https://www.epa.gov/ground-water-and-drinking-water/national-primary-drinking-water-regulation-table>

IMS IMS = IMMEDIATE METAL SAMPLE.  
(INTERPRETATION: WATER SAMPLED AFTER SITTING UNDISTURBED  
A MINIMUM OF 6 HOURS OR OVERNIGHT)

THE ABOVE TEST PROCEDURES MEET ALL REQUIREMENTS OF NELAC,  
AND RELATE ONLY TO THESE SAMPLES RECEIVED BY THE LAB

SUBMITTED BY:   
Albert H. Padovani, M.T. (ASCP)  
Director

ELAP# 10323

YML ENVIRONMENTAL SERVICES  
321 Kear Street  
Yorktown Heights, N.Y. 10598  
(914) 245-2800  
Albert H. Padovani, Director  
\*\* TEST REPORT \*\*

LAB #: 1.003665 CLIENT #: 551 NON STAT PROC PAGE: 1 of 1

PUTNAM VALLEY CENTRAL  
146 PEEKSKILL HOLLOW RD  
ATTN: DAVID SPITTAL  
PUTNAM VALLEY, NY 10579

DATE/TIME TAKEN: 10/24/20 10:06A  
DATE/TIME REC'D: 10/26/20 11:40A  
REPORT DATE: 11/06/20  
PHONE: (845)-526-7854

SAMPLING SITE: PUTNAM VALLEY SCHOOL DISTRICT  
: ADMIN BLDG LEFT SINK  
COL'D BY: CAREY CLERICI  
NOTES...:

SAMPLE TYPE...: POTABLE  
PRESERVATIVES: HNO3  
TEMP RECEIVED: 20C NOT ON ICE  
COLIFORM METH: N/A

START DATE/TIME	END DATE/TIME	FLAG	PROCEDURE	RESULT	NORMAL - RANGE	METHOD
10/30/20			LEAD (IMS)	5.1 ppb	0-15 ppb	SM 22 3113B

COMMENTS:

Pb/Cu LEAD limits for public schools are set at 15 ppb.  
EPA Lead & Copper Rule for Public Systems requires that no more than 10% of their distribution points have a LEAD value of more than 15 ppb and a COPPER value of 1.3 mg/L, else water treatment must be undertaken to reduce the waters corrosive potential.

NRR 'NORMAL-RANGE' REFERENCE=  
U.S. ENVIRONMENTAL PROTECTION AGENCY (EPA); MAY 2009  
NATIONAL PRIMARY DRINKING WATER REGULATIONS  
VISIT: <https://www.epa.gov/ground-water-and-drinking-water/national-primary-drinking-water-regulation-table>

IMS IMS = IMMEDIATE METAL SAMPLE.  
(INTERPRETATION: WATER SAMPLED AFTER SITTING UNDISTURBED  
A MINIMUM OF 6 HOURS OR OVERNIGHT)

THE ABOVE TEST PROCEDURES MEET ALL REQUIREMENTS OF NELAC,  
AND RELATE ONLY TO THESE SAMPLES RECEIVED BY THE LAB

SUBMITTED BY:   
Albert H. Padovani, M.T. (ASCP)  
Director

ELAP# 10323

YML ENVIRONMENTAL SERVICES  
321 Kear Street  
Yorktown Heights, N.Y. 10598  
(914) 245-2800  
Albert H. Padovani, Director  
\*\* TEST REPORT \*\*

LAB #: 1.003666 CLIENT #: 551 NON STAT PROC PAGE: 1 of 1

PUTNAM VALLEY CENTRAL  
146 PEEKSKILL HOLLOW RD  
ATTN: DAVID SPITTAL  
PUTNAM VALLEY, NY 10579

DATE/TIME TAKEN: 10/24/20 10:07A  
DATE/TIME REC'D: 10/26/20 11:40A  
REPORT DATE: 11/06/20  
PHONE: (845)-526-7854

SAMPLING SITE: PUTNAM VALLEY SCHOOL DISTRICT  
: ADMIN BLDG RIGHT SINK  
COL'D BY: CAREY CLERICI  
NOTES....:

SAMPLE TYPE...: POTABLE  
PRESERVATIVES: HNO3  
TEMP RECEIVED: 20C NOT ON ICE  
COLIFORM METH: N/A

START DATE/TIME	END DATE/TIME	FLAG	PROCEDURE	RESULT	NORMAL - RANGE	METHOD
10/30/20			LEAD (IMS)	<1.0 ppb	0-15 ppb	SM 22 3113B


COMMENTS:

Pb/Cu LEAD limits for public schools are set at 15 ppb.  
EPA Lead & Copper Rule for Public Systems requires that no more than 10% of their distribution points have a LEAD value of more than 15 ppb and a COPPER value of 1.3 mg/L, else water treatment must be undertaken to reduce the waters corrosive potential.

NRR 'NORMAL-RANGE' REFERENCE=  
U.S. ENVIRONMENTAL PROTECTION AGENCY (EPA); MAY 2009  
NATIONAL PRIMARY DRINKING WATER REGULATIONS  
VISIT: <https://www.epa.gov/ground-water-and-drinking-water/national-primary-drinking-water-regulation-table>

IMS IMS = IMMEDIATE METAL SAMPLE.  
(INTERPRETATION: WATER SAMPLED AFTER SITTING UNDISTURBED  
A MINIMUM OF 6 HOURS OR OVERNIGHT)

THE ABOVE TEST PROCEDURES MEET ALL REQUIREMENTS OF NELAC,  
AND RELATE ONLY TO THESE SAMPLES RECEIVED BY THE LAB

SUBMITTED BY:   
Albert H. Padovani, M.T. (ASCP)  
Director

ELAP# 10323